



Residence_TAN (1)
Residence_TAN Analysis

Analyzed at 12/14/2017 8:51:35 AM

Energy Analysis Result



Building Performance Factors

| | |
|-------------------------|--------------------------|
| Location: | Creede, CO |
| Weather Station: | 19405 |
| Outdoor Temperature: | Max: 88°F/Min: -30°F |
| Floor Area: | 3,077 sf |
| Exterior Wall Area: | 2,674 sf |
| Average Lighting Power: | 0.26 W / ft ² |
| People: | 1 people |
| Exterior Window Ratio: | 0.11 |
| Electrical Cost: | \$0.11 / kWh |
| Fuel Cost: | \$0.78 / Therm |

Energy Use Intensity

| | |
|------------------|-------------------|
| Electricity EUI: | 15 kWh / sf / yr |
| Fuel EUI: | 13 kBtu / sf / yr |
| Total EUI: | 66 kBtu / sf / yr |

Life Cycle Energy Use/Cost

| | |
|-----------------------------|--------------|
| Life Cycle Electricity Use: | 852,656 kWh |
| Life Cycle Fuel Use: | 7,360 Therms |
| Life Cycle Energy Cost: | \$44,270 |


*30-year life and 6.1% discount rate for costs

Renewable Energy Potential


| | |
|---|-----------------|
| Roof Mounted PV System (Low efficiency): | 11,504 kWh / yr |
| Roof Mounted PV System (Medium efficiency): | 23,008 kWh / yr |
| Roof Mounted PV System (High efficiency): | 34,512 kWh / yr |
| Single 15' Wind Turbine Potential: | 893 kWh / yr |

*PV efficiencies are assumed to be 5%, 10% and 15% for low, medium and high efficiency systems


Annual Carbon Emissions




Annual Energy Use/Cost



Energy Use: Fuel




Energy Use: Electricity




| | | | (kWh) |
|----------------|-----|---------|--------|
| HVAC | 89% | \$2,718 | 25,268 |
| Lighting | 5% | \$170 | 1,584 |
| Misc Equipment | 6% | \$168 | 1,568 |
| | | \$3,056 | 28,420 |


Monthly Heating Load




Monthly Cooling Load




Monthly Fuel Consumption




Monthly Electricity Consumption




Monthly Peak Demand




Annual Wind Rose (Speed Distribution)




Annual Wind Rose (Frequency Distribution)




Monthly Wind Roses




Monthly Design Data




Annual Temperature Bins



Diurnal Weather Averages



Humidity



© Copyright 2015 Autodesk, Inc. All rights reserved. Portions of this software are copyrighted by James J. Hirsch & Associates, the Regents of the University of California, and others.

Energy Analysis Data

Project Summary

| Location and Weather | |
|----------------------|--------------------------------------|
| Project | Home Energy Analysis |
| Address | Creede, Colorado |
| Calculation Time | Thursday, December 07, 2017 11:25 AM |
| Report Type | Simple |
| Latitude | 37.85° |
| Longitude | -106.93° |
| Summer Dry Bulb | 86 °F |
| Summer Wet Bulb | 60 °F |
| Winter Dry Bulb | -17 °F |
| Mean Daily Range | 32 °F |

Building Summary

| Inputs | |
|---|-----------------|
| Building Type | Single Family |
| Area (SF) | 2,332 |
| Volume (CF) | 21,960 |
| Calculated Results | |
| Peak Cooling Total Load (Btu/h) | 17,457.4 |
| Peak Cooling Month and Hour | July 4:00 PM |
| Peak Cooling Sensible Load (Btu/h) | 18,523.3 |
| Peak Cooling Latent Load (Btu/h) | -1,065.9 |
| Maximum Cooling Capacity (Btu/h) | 17,494.6 |
| Peak Cooling Airflow (CFM) | 772 |
| Peak Heating Load (Btu/h) | 24,978.6 |
| Peak Heating Airflow (CFM) | 2,142 |
| Checksums | |
| Cooling Load Density (Btu/(h·ft ²)) | 7.49 |
| Cooling Flow Density (CFM/SF) | 0.33 |
| Cooling Flow / Load (CFM/ton) | 530.49 |
| Cooling Area / Load (SF/ton) | 1,602.67 |
| Heating Load Density (Btu/(h·ft ²)) | 10.71 |
| Heating Flow Density (CFM/SF) | 0.92 |

Zone Summary - Zone 1

| | |
|---|---------------------|
| Inputs | |
| Area (SF) | 1,182 |
| Volume (CF) | 12,124 |
| Cooling Setpoint | 74 °F |
| Heating Setpoint | 70 °F |
| Supply Air Temperature | 54 °F |
| Air Volume Calculation Type | VAV - Single Duct |
| Relative Humidity | 42.00% (Calculated) |
| Psychrometric Message | None |
| Calculated Results | |
| Peak Cooling Load (Btu/h) | 8,291.6 |
| Peak Cooling Month and Hour | July 5:00 PM |
| Peak Cooling Sensible Load (Btu/h) | 8,777.6 |
| Peak Cooling Latent Load (Btu/h) | -486.0 |
| Peak Cooling Airflow (CFM) | 365 |
| Peak Heating Load (Btu/h) | 11,880.1 |
| Peak Heating Airflow (CFM) | 1,019 |
| Checksums | |
| Cooling Load Density (Btu/(h-ft ²)) | 7.01 |
| Cooling Flow Density (CFM/SF) | 0.31 |
| Cooling Flow / Load (CFM/ton) | 528.21 |
| Cooling Area / Load (SF/ton) | 1,710.82 |
| Heating Load Density (Btu/(h-ft ²)) | 10.05 |
| Heating Flow Density (CFM/SF) | 0.86 |

Zone 1 Spaces

| Space Name | Area (SF) | Volume (CF) | Peak Cooling Load (Btu/h) | Cooling Airflow (CFM) | Peak Heating Load (Btu/h) | Heating Airflow (CFM) |
|---------------|-----------|-------------|---------------------------|-----------------------|---------------------------|-----------------------|
| 107 BEDROOM | 203 | 2,032 | 1,679.6 | 45 | 2,435.0 | 209 |
| 121 CLOSET1 | 30 | 363 | 68.0 | 3 | 121.3 | 10 |
| 122 1/2 Hall | 12 | 170 | 20.4 | 1 | 58.1 | 5 |
| 108 MECH | 60 | 513 | 195.7 | 8 | 419.7 | 36 |
| 109 WIC | 42 | 323 | 163.8 | 6 | 620.3 | 53 |
| 126 CLOSET2 | 32 | 395 | 73.6 | 3 | 126.9 | 11 |
| 110 LOFT | 383 | 3,971 | 2,808.1 | 126 | 3,385.9 | 290 |
| 123 GREATROOM | 395 | 4,047 | 3,959.2 | 172 | 4,712.9 | 404 |

Zone Summary - Zone 2

| Inputs | |
|---|---------------------|
| Area (SF) | 1,183 |
| Volume (CF) | 10,216 |
| Cooling Setpoint | 74 °F |
| Heating Setpoint | 70 °F |
| Supply Air Temperature | 54 °F |
| Air Volume Calculation Type | VAV - Single Duct |
| Relative Humidity | 42.00% (Calculated) |
| Psychrometric Message | None |
| Calculated Results | |
| Peak Cooling Load (Btu/h) | 9,203.0 |
| Peak Cooling Month and Hour | July 4:00 PM |
| Peak Cooling Sensible Load (Btu/h) | 9,783.0 |
| Peak Cooling Latent Load (Btu/h) | -579.9 |
| Peak Cooling Airflow (CFM) | 407 |
| Peak Heating Load (Btu/h) | 13,098.5 |
| Peak Heating Airflow (CFM) | 1,123 |
| Checksums | |
| Cooling Load Density (Btu/(h-ft ²)) | 7.78 |
| Cooling Flow Density (CFM/SF) | 0.34 |
| Cooling Flow / Load (CFM/ton) | 530.40 |
| Cooling Area / Load (SF/ton) | 1,542.54 |
| Heating Load Density (Btu/(h-ft ²)) | 11.07 |
| Heating Flow Density (CFM/SF) | 0.95 |

Zone 2 Spaces

| Space Name | Area (SF) | Volume (CF) | Peak Cooling Load (Btu/h) | Cooling Airflow (CFM) | Peak Heating Load (Btu/h) | Heating Airflow (CFM) |
|--------------------|-----------|-------------|---------------------------|-----------------------|---------------------------|-----------------------|
| 114 MASTER BEDROOM | 203 | 1,651 | 2,504.5 | 51 | 2,323.1 | 199 |
| 116 WIC | 42 | 341 | 75.1 | 2 | 242.6 | 21 |
| 115 BATHROOM | 60 | 492 | 1,204.2 | 16 | 928.9 | 80 |
| 118 1/2 BATH | 24 | 194 | 22.9 | 1 | 0.0 | 0 |
| 117 LAUNDRY | 50 | 407 | 117.9 | 4 | 347.2 | 30 |
| 7 1/2 Hall | 17 | 140 | 16.6 | 1 | 0.0 | 0 |
| 112 DINING | 175 | 1,749 | 3,680.7 | 161 | 2,136.4 | 183 |
| 113 GREAT ROOM | 289 | 2,557 | 1,067.1 | 47 | 2,832.3 | 243 |
| 119 MUD ROOM | 115 | 995 | 785.0 | 24 | 1,593.3 | 137 |
| 111 KITCHEN | 199 | 1,621 | 2,390.7 | 101 | 2,694.7 | 231 |

Adam Scott,

Please see the following report summarizing the information found through our energy analysis.

Project Information:

Residence, New Construction

Client-

Location- Creede, Colorado

Building performance-

Single Family Home

Area - 2360 sq. ft.

Climate Zone – Zone 7

The building loads from the heating and cooling calculation shows an extremely energy efficient home that exceeds 1000 sq. ft. per ton of cooling. Our calculation states that your home will be running at 1500 sf per ton. The recommended HVAC unit size for the Saunders residence would be a 2 ton unit. We would recommend an efficient HVAC system as in a VRF system to utilize the most utility savings opportunities. Some savings opportunities were analyzed to reduce energy use and save the home owner energy costs.

Saving opportunities:

Below are the highest opportunities to save on energy cost and energy intensity usage based on our energy model. As you can see below, the savings opportunities on the building design are not great due to the efficiency of the current design.

1) Roof Construction:

By increasing the thermal resistance values on the current roof construction, the heat loss across the wall can be reduced leading to higher energy savings.

A 10 ¼ SIP can create an efficient home but by doubling the R value of the roof construction to an R60, this can create energy savings, roughly 2 cents per sq. foot per year. This savings value equates to roughly 50\$ per year. The payback is minimal for the construction change and we believe the current design now is optimal.

2) Wall construction:

By increasing the thermal resistance values on the current wall construction, the heat loss across the wall can be reduced leading to higher energy savings.

By doubling the size of the structurally insulated panel system to 12 ¼” SIP, the savings would roughly be 8-10 cents per sq. foot per year. This savings could lead to roughly 200\$ per year in energy savings. This is a large change in wall construction for a minimal payback and we believe the current wall construction is optimal.

3) Window Composition:

Major heat loss occurs through the windows in residential homes. By upgrading windows, the cost savings is more effective compared to other construction factors.

The emissivity of window is another energy factor to consider. A low-e Pella Proline Series window is expected to be installed. Double pane windows with a low-e (e= 0.05) can reduce the heat loss by over 8000 Btu/hr in the entire home resulting in energy savings compared to a higher emissivity rating (e=0.2). Consider costs of materials when upgrading the composition of the windows. Upgrading rooms with greater window area or in path of direct sunlight will lead to even higher energy savings and/or HVAC system sizing reduction.

Windows Emissivity and Cooling Capacity:

- Double Pane
 - $e = 0.2/0.1/0.05 \rightarrow 18,284.6/18,292.9/13,461.7$ Btu/hr
- Triple pane
 - $e = 0.2/0.1/0.05 \rightarrow 16,914.0/13,104.9/10,518.0$ Btu/hr

*All other construction elements are maintained according to the construction drawings.

By upgrading windows, the recommended 2 ton unit can be reduced to a 1 ½ ton unit and possibly a 1 ton unit. The sizing may be reduced based on owner preference and usage.

4) Electrical Design:

These are savings shown to us on assumed values for electrical load. Energy savings on the home based on electrical inputs can be large and should be considered.

Based on the electrical input (1 W/sf) that was selected for this model the energy analysis shows that by having a lighting efficiency of .3 W/sf could allow the owners to save 10 cents/sf/year in energy costs. That is a savings of over 236\$ per year in energy costs.

The model also takes into account plug load efficiency. Our input for plug load efficiency chosen was 1 W/sf. By lowering this value to .6 W/sf, the owners may save up to 10 cents/sf/year, which will greatly impact energy savings on the home. This savings could yield up to a 236\$ savings per year in energy costs.

The energy savings listed must be evaluated vs the increased cost to make the change, as these changes could only lead to minimal return if the construction cost is large. Based on our modeling we believe that the designed home is extremely energy efficient, and should only require a 2 ton HVAC unit to make the space comfortable. An important point to make to the owner is that they should be selecting the correct HVAC system and size for optimal energy savings.

Performance Recommendations:

The following recommendations are to be considered when designing the home for even greater energy and utilities savings

- Avoiding oversized HVAC system leads to mechanical cost savings.
- Install Energy Star rated appliances including but not limited to water heaters, washing and drying machines, refrigerators, and dishwashing machines.
- Use low flow plumbing fixtures to reduce water consumption.
- Roof construction materials and light reflective options to reduce heat transfer and absorption through the roof.

HVAC Load Breakdown:

- Upper Floor
 - Cooling
 - 9800 Btu/hr (54% of total load)
 - Heating
 - 12600 Btu/hr
 - Lower Floor
 - Cooling
 - 8500 Btu/hr (46% of total load)
 - Heating
 - 12000 Btu/hr
-
- Total Load
 - Cooling
 - 18300 Btu/hr (roughly 1.52 tons → 2 ton unit)
 - Heating
 - 25000 Btu/hr

If there are any other factors that you would think about changing we can add them into the model and compare the results.

Thank you.

John F. Daly, P.E.
Vice President